From: Paul Mitchell
To: Kern, Chris (CPC); Joyce
Subject: RE: SFPUC Comment memo on Warriors Arena -
Date: Wednesday, October 29, 2014 3:44:06 PM

Yes, agreed. Do you want to forward this to the sponsor, or would you like me to (and I can point out the change to them)?

-Paul

From: Kern, Chris (CPC) [mailto:chris.kern@sfgov.org]
Sent: Wednesday, October 29, 2014 3:42 PM
To: Paul Mitchell; Joyce
Subject: RE: SFPUC Comment memo on Warriors Arena -

Okay – I think we can live with this as is as it clarifies that the hydraulic analysis is not required for environmental review.

Chris Kern
Senior Environmental Planner

Planning Department, City and County of San Francisco
1650 Mission Street, Suite 400, San Francisco, CA 94103
Direct: 415-575-9037 **Fax:** 415-558-6409
Email: chris.kern@sfgov.org
Web: www.sfplanning.org

From: Paul Mitchell [mailto:PMitchell@esassoc.com]
Sent: Wednesday, October 29, 2014 3:37 PM
To: Kern, Chris (CPC); Joyce
Subject: RE: SFPUC Comment memo on Warriors Arena -

...clarified my response, below (in highlighted yellow)

From: Paul Mitchell
Sent: Wednesday, October 29, 2014 3:35 PM
To: 'Kern, Chris (CPC)'; Joyce
Subject: RE: SFPUC Comment memo on Warriors Arena -

Chris;

Thanks. Upon review, it appears the only thing different is that the second to last bulleted item on page 3 from the October 7, 2014 SFPUC memo:

p. 63 - 65, Water Supply
• Impact UT-1. A hydraulic analysis of the project is required to determine if the existing SFPUC water distribution system is sufficient to meet the project's potable and fire suppression demands.

....is replaced with the following bulleted item in the October 29, 2014 SFPUC memo (last bulleted

item on page 3 of new memo):

p. 63 - 65, Water Supply
• Impact UT-1. Prior to approval by SFPUC to obtain new water service, the project sponsor will be required to request a hydraulic analysis of the SFPUC water distribution system to confirm that the existing water distribution system is adequate to meet the proposed project's fire suppression system pressure and flow demands. If the existing water distribution system is inadequate to meet the project demands, the project sponsor will be responsible for the construction of any required new water mains and appurtenances.

-Paul

From: Kern, Chris (CPC) [mailto:chris.kern@sfgov.org]
Sent: Wednesday, October 29, 2014 3:22 PM
To: Paul Mitchell; Joyce
Subject: FW: SFPUC Comment memo on Warriors Arena -

This just in (I haven't read it yet).

Chris Kern
Senior Environmental Planner

Planning Department, City and County of San Francisco
1650 Mission Street, Suite 400, San Francisco, CA 94103
Direct: 415-575-9037 **Fax:** 415-558-6409
Email: chris.kern@sfgov.org
Web: www.sfplanning.org

From: Frye, Karen [mailto:KFrye@sfwater.org]
Sent: Wednesday, October 29, 2014 3:09 PM
To: Reilly, Catherine (CII); Kern, Chris (CPC)
Cc: Torrey, Irina (PUC)
Subject: SFPUC Comment memo on Warriors Arena -

Please see SFPUC's comment memo attached (replaces the previous memo sent on Oct 7, which you can delete). Thank you

Karen E. Frye, AICP
San Francisco Water, Power and Sewer | Services of the San Francisco Public Utilities Commission
Bureau of Environmental Management
525 Golden Gate Avenue, 6th Floor
San Francisco, CA 94102
415-554-1652 (office)
415-694-1227 (cell)

Delivering excellence in the environmental review and permitting process through teamwork, knowledge, integrity, and respect.